

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	RECOMMENDATIONS
				DAM	QUANTITY		ASSESSMENT 40 CFR 763.88	ACTION START/END DATES	CLEANING NEEDED	OF DAMAGE	
1	GREY 9' X 9" VINYL FLOOR TILE										
	ROOM 111		A	N	750 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 113			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 116			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 205			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	STORAGE E			N	225 SF	NF	5		N		GOOD CONDITION - O&M
	SHOPS/OFFICE			N	125 SF	NF	5		N		GOOD CONDITION - O&M
	MAIN OFFICE CLOSET			N	12 SF	NF	5		N		GOOD CONDITION - O&M
	MAIN OFFICE VAULT			N	60 SF	NF	5		N		GOOD CONDITION - O&M
	KITCHEN STORAGE ROOM			N	250 SF	NF	5		N		GOOD CONDITION - O&M
	ELECTRIC ROOM BY 116			N	120 SF	NF	5		N		GOOD CONDITION - O&M
	2	MASTIC FOR GREY 9' X 9" VINYL FLOOR TILE									
ROOM 111			A	N	750 SF	NF	5		N		GOOD CONDITION - O&M
ROOM 113				N	750 SF	NF	5		N		GOOD CONDITION - O&M
ROOM 116				N	750 SF	NF	5		N		GOOD CONDITION - O&M
ROOM 205				N	750 SF	NF	5		N		GOOD CONDITION - O&M
STORAGE E				N	225 SF	NF	5		N		GOOD CONDITION - O&M
SHOPS/OFFICE				N	125 SF	NF	5		N		GOOD CONDITION - O&M
MAIN OFFICE CLOSET				N	12 SF	NF	5		N		GOOD CONDITION - O&M
MAIN OFFICE VAULT				N	60 SF	NF	5		N		GOOD CONDITION - O&M
KITCHEN STORAGE ROOM				N	250 SF	NF	5		N		GOOD CONDITION - O&M
ELECTRIC ROOM BY 116				N	120 SF	NF	5		N		GOOD CONDITION - O&M
3		BROWN 9' X 9" VINYL FLOOR TILE									
	HALLWAYS TO SHOPS		A	N	340 SF	NF	5		N		GOOD CONDITION - O&M
	KITCHEN BATHROOM			N	80 SF	NF	5		N		GOOD CONDITION - O&M
4	MASTIC FOR BROWN 9' X 9" VINYL FLOOR TILE										
	HALLWAYS TO SHOPS		A	N	340 SF	NF	5		N		GOOD CONDITION - O&M
	KITCHEN BATHROOM			N	80 SF	NF	5		N		GOOD CONDITION - O&M

ASBESTOS TYPE

CHRY Chrysotile

AMOS Amosite

ACTI Actinolite

ANTH Anthophyllite

CROC Crocidolite

NA/PS Not Analyzed/Positive Stop

QUANTITY

SF Square Feet

LF Linear Feet

EA Each

TO Total

TYPE OF MATERIAL

M Miscellaneous

S Surfacing

T Thermal

ASBESTOS

Y Yes

N No

A Assumed

NOTES

HV - HEPA VACCUUM

2X/WK - TWICE PER WEEK

1X/WK - ONCE PER WEEK

L - LOOSE

DE - DETERRIORATED

D - DAMAGED

SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	RECOMMENDATIONS
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES
5	GREEN 9' X 9" VINYL FLOOR TILE										
	CUSTODIAN ROOM BY ROOM 106		A	N	75 SF	NF	5		N		GOOD CONDITION - O&M
6	MASTIC FOR GREEN 9' X 9" VINYL FLOOR TILE										
	CUSTODIAN ROOM BY ROOM 106		A	N	75 SF	NF	5		N		GOOD CONDITION - O&M
7	BLACK 9' X 9" VINYL FLOOR TILE										
	COPY ROOM		A	N	100 SF	NF	5		N		GOOD CONDITION - O&M
	AUDITORIUM STAIRS UP TO CATWALK			N	75 SF	NF	5		N		GOOD CONDITION - O&M
	STORAGE NEXT TO COPY ROOM			N	100 SF	NF	5		N		GOOD CONDITION - O&M
	ELECTRIC ROOM BY CAFETERIA			N	60 SF	NF	5		N		GOOD CONDITION - O&M
	SPRINKLER ROOM BY CAFETERIA			N	300 SF	NF	5		N		GOOD CONDITION - O&M
8	MASTIC FOR BLACK 9' X 9" VINYL FLOOR TILE										
	COPY ROOM		A	N	100 SF	NF	5		N		GOOD CONDITION - O&M
	AUDITORIUM STAIRS UP TO CATWALK			N	75 SF	NF	5		N		GOOD CONDITION - O&M
	STORAGE NEXT TO COPY ROOM			N	100 SF	NF	5		N		GOOD CONDITION - O&M
	ELECTRIC ROOM BY CAFETERIA			N	60 SF	NF	5		N		GOOD CONDITION - O&M
9	GREEN/BLUE 9' X 9" VINYL FLOOR TILE										
	CAFETERIA		A	N	5,000 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 102			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	STORAGE B			N	125 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 104			N	750 SF	NF	5		N		GOOD CONDITION - O&M
10	MASTIC FOR GREEN/BLUE 9' X 9" VINYL FLOOR TILE										
	CAFETERIA		A	N	5,000 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 102			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	STORAGE B			N	125 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 104			N	750 SF	NF	5		N		GOOD CONDITION - O&M

ASBESTOS TYPE

CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY

SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL

M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS

Y Yes  
N No  
A Assumed

NOTES

HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	
				ASSESSMENT	ACTION		CLEANING	OF	RECOMMENDATIONS		
				40 CFR 763.88	START/END DATES		NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES		
11	BLUE/GREY 12" X 12" VINYL FLOOR TILE										
	AUDITORIUM TICKET OFFICE	12/28/22	N	N N	6,200 SF 100 SF						
12	MASTIC FOR BLUE/GREY 12" X 12" VINYL FLOOR TILE										
	AUDITORIUM TICKET OFFICE	12/28/22	N	N N	6,200 SF 100 SF						
13	DARK BLUE 12" X 12" VINYL FLOOR TILE										
	PRACTICE ROOMS AND HALLS NEAR STAGE KITCHEN OFFICE	12/28/22	N	N N	525 SF 40 SF						
14	MASTIC FOR DARK BLUE 12" X 12" VINYL FLOOR TILE										
	PRACTICE ROOMS AND HALLS NEAR STAGE KITCHEN OFFICE	12/28/22	N	N N	525 SF 40 SF						
15	LIGHT CHOCOLATE 12" X 12" VINYL FLOOR TILE										
	MAIN LOBBY AND HALLWAYS TO FINE ARTS	12/28/22	Y	N	2,000 SF	NF	5		N		GOOD CONDITION - O&M
16	LIGHT CHOCOLATE 12" X 12" VINYL FLOOR TILE										
	MAIN LOBBY AND HALLWAYS TO FINE ARTS	12/28/22	Y	N	2,000 SF	NF	5		N		GOOD CONDITION - O&M
17	INTERIOR WINDOW CAULKING										
	MAIN OFFICE, ROOM 102 WING, CAFETERIA ROOM 208 WING, ROOM 124 WING, ROOM 114 WING	7/9/10	Y	N	200 TO	NF	5		N		GOOD CONDITION - O&M

ASBESTOS TYPE  
CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY  
SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL  
M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS  
Y Yes  
N No  
A Assumed

NOTES  
HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	RECOMMENDATIONS
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES
18	SINK DAMPROOFING										
	LANGUAGE OFFICE		A	N	1 TO	NF	5		N		GOOD CONDITION - O&M
	ART CLASSROOM			N	1 TO	NF	5		N		GOOD CONDITION - O&M
	ENGLISH DEPARTMENT			N	6 TO	NF	5		N		GOOD CONDITION - O&M
	MATH-SCIENCE DEPARTMENT			N	1 TO	NF	5		N		GOOD CONDITION - O&M
	ROOM 209			N	3 TO	NF	5		N		GOOD CONDITION - O&M
19	INTERIOR DOORS WITH CAULKING										
	CLASSROOMS ENTRANCE DOORS	7/9/10	Y	N	40 TO	NF	5		N		GOOD CONDITION - O&M
	SHOPS DOORS										
	CAFETERIA DOORS										
20	CEILING/WALL PLASTER										
	CLASSROOMS	7/9/10	N	N	150,000 SF						
	HALLWAYS										
	OFFICES										
	STORAGE ROOMS										
	BATHROOMS										
	AUDITORIUM										
21	1' X 1' ACOUSTICAL CEILING TILE										
	LOUNGE	7/9/10	N	N	6,500 SF						
	CAFETERIA										
	CADD ROOM 305										
	STORAGE NEXT TO COPY ROOM										
22	JOINT COMPOUND										
	CLASSROOMS	7/9/10	N	N	65,000 SF						
	HALLWAYS										
	OFFICES										
23	HARD JOINT INSULATION										
	BATHROOMS	7/9/10	N	N	100 TO						
	STORAGE ROOMS										

ASBESTOS TYPE  
CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY  
SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL  
M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS  
Y Yes  
N No  
A Assumed

NOTES  
HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	RECOMMENDATIONS
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	REFER TO REPORT FOR DATES AND COST ESTIMATES
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	
24	WHITE/BLUE 12" X 12" VINYL FLOOR TILE										
	ROOM 110	12/28/22	N	N	750 SF						
25	MASTIC FOR WHITE/BLUE 12" X 12" VINYL FLOOR TILE										
	ROOM 110	12/28/22	Y	N	750 SF	NF	5		N		GOOD CONDITION - O&M
26	BLACK/WHITE SPOTS 12" X 12" VINYL FLOOR TILE										
	ROOM 300	12/28/22	N	N	820 SF						
27	MASTIC FOR BLACK/WHITE SPOTS 12" X 12" VINYL FLOOR TILE										
	ROOM 300	12/28/22	N	N	820 SF						
28	SCIENCE LAB COUNTER TOPS										
	ROOM 120		A	N	21 TO	NF	5		N		GOOD CONDITION - O&M
	ROOM 122			N	20 TO	NF	5		N		GOOD CONDITION - O&M
	ROOM 124			N	28 TO	NF	5		N		GOOD CONDITION - O&M
	ROOM 126			N	28 TO	NF	5		N		GOOD CONDITION - O&M
	ROOM 128			N	21 TO	NF	5		N		GOOD CONDITION - O&M
29	LIGHT CRÈME 12" X 12" VINYL FLOOR TILE										
	ROOM 106	12/28/22	N	N	900 SF						
	ROOM 100			N	900 SF						
	ENGLISH DEPARTMENT			N	1,600 SF						
	HEALTH			N	600 SF						
	ROOM 105			N	720 SF						
	ROOM 103			N	720 SF						

ASBESTOS TYPE  
CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY  
SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL  
M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS  
Y Yes  
N No  
A Assumed

NOTES  
HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	RECOMMENDATIONS
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES
29	LIGHT CRÈME 12" X 12" VINYL FLOOR TILE										
	ROOM 101	12/28/22	N	N	500 SF						
	COMMUNICATIONS CLOSET			N	100 SF						
	RESOURCES OFFICE			N	70 SF						
	MAIN OFFICE			N	200 SF						
	ROOM 108			N	900 SF						
	ROOM 107			N	900 SF						
	ROOM 109			N	900 SF						
	ROOM 112			N	900 SF						
	ROOM 114			N	900 SF						
	ROOM 120			N	1,100 SF						
	ROOM 122			N	1,100 SF						
	MATH-SCIENCE DEPARTMENT			N	900 SF						
	ROOM 124			N	1,200 SF						
	MATH-SCIENCE COMPUTER LAB			N	600 SF						
	ROOM 121			N	750 SF						
	ROOM 126			N	1,200 SF						
	ROOM 123			N	750 SF						
	ROOM 128			N	1,200 SF						
	ROOM 125			N	750 SF						
	NETWORK CONTROL STORAGE D			N	140 SF						
	ROOM 200			N	900 SF						
	ROOM 201			N	900 SF						
	ROOM 202			N	900 SF						
	ROOM 203			N	900 SF						
	ROOM 204			N	900 SF						
	ROOM 206			N	900 SF						
	ROOM 207			N	570 SF						
	ROOM 208			N	570 SF						
	ROOM 209			N	1,500 SF						
	ROOM 210			N	450 SF						
	ROOM 212			N	450 SF						
	READING/SPEECH OFFICE			N	100 SF						
	FACULTY ROOM			N	460 SF						
	OFFICE B			N	100 SF						
	OFFICE C			N	100 SF						
CONFERENCE ROOM	N			230 SF							
YEARBOOK OFFICE	N	100 SF									
LIBRARY OFFICE	N	500 SF									
ROOM 401 ART	N	1,200 SF									

ASBESTOS TYPE

CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY

SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL

M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS

Y Yes  
N No  
A Assumed

NOTES

HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE	RECOMMENDATIONS
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES
29	LIGHT CRÈME 12" X 12" VINYL FLOOR TILE	12/28/22	N								
	ROOM 404 HEALTH			N	600 SF						
	MAIN HALLWAYS			N	8,000 SF						
	ROOM 301 MUSIC			N	1,600 SF						
	ROOM 305 CADD RISE			N	600 SF						
	ROOM 99 CONFERENCE			N	460 SF						
30	MASTIC FOR LIGHT CRÈME 12" X 12" VINYL FLOOR TILE	12/28/22	Y								
	ROOM 106			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 100			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ENGLISH DEPARTMENT			N	1,600 SF	NF	5		N		GOOD CONDITION - O&M
	HEALTH			N	600 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 105			N	720 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 103			N	720 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 101			N	500 SF	NF	5		N		GOOD CONDITION - O&M
	COMMUNICATIONS CLOSET			N	100 SF	NF	5		N		GOOD CONDITION - O&M
	RESOURCES OFFICE			N	70 SF	NF	5		N		GOOD CONDITION - O&M
	MAIN OFFICE			N	200 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 108			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 107			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 109			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 112			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 114			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 120			N	1,100 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 122			N	1,100 SF	NF	5		N		GOOD CONDITION - O&M
	MATH-SCIENCE DEPARTMENT			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 124			N	1,200 SF	NF	5		N		GOOD CONDITION - O&M
	MATH-SCIENCE COMPUTER LAB			N	600 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 121			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 126			N	1,200 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 123			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 128			N	1,200 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 125			N	750 SF	NF	5		N		GOOD CONDITION - O&M
	NETWORK CONTROL STORAGE D			N	140 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 200			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 201			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 202			N	900 SF	NF	5		N		GOOD CONDITION - O&M
	ROOM 203			N	900 SF	NF	5		N		GOOD CONDITION - O&M

ASBESTOS TYPE

CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY

SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL

M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS

Y Yes  
N No  
A Assumed

NOTES

HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	2022	RESPONSE	SPECIAL	TYPE		
				DAM	QUANTITY		ASSESSMENT	ACTION	CLEANING	OF	RECOMMENDATIONS	
							40 CFR 763.88	START/END DATES	NEEDED	DAMAGE	REFER TO REPORT FOR DATES AND COST ESTIMATES	
30	MASTIC FOR LIGHT CRÈME 12" X 12" VINYL FLOOR TILE	12/28/22	Y									
	ROOM 204			N	900 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 206			N	900 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 207			N	570 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 208			N	570 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 209			N	1,500 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 210			N	450 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 212			N	450 SF	NF	5		N		GOOD CONDITION - O&M	
	READING/SPEECH OFFICE			N	100 SF	NF	5		N		GOOD CONDITION - O&M	
	FACULTY ROOM			N	460 SF	NF	5		N		GOOD CONDITION - O&M	
	OFFICE B			N	100 SF	NF	5		N		GOOD CONDITION - O&M	
	OFFICE C			N	100 SF	NF	5		N		GOOD CONDITION - O&M	
	CONFERENCE ROOM			N	230 SF	NF	5		N		GOOD CONDITION - O&M	
	YEARBOOK OFFICE			N	100 SF	NF	5		N		GOOD CONDITION - O&M	
	LIBRARY OFFICE			N	500 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 401 ART			N	1,200 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 404 HEALTH			N	600 SF	NF	5		N		GOOD CONDITION - O&M	
	MAIN HALLWAYS			N	8,000 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 301 MUSIC			N	1,600 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 305 CADD RISE			N	600 SF	NF	5		N		GOOD CONDITION - O&M	
	ROOM 99 CONFERENCE			N	460 SF	NF	5		N		GOOD CONDITION - O&M	
	31			2' X 2' SUSPENDED ACOUSTICAL CEILING TILE	7/9/10	N						
ROOM 106		N	900 SF									
ROOM 104		N	900 SF									
ROOM 102		N	900 SF									
ROOM 100		N	900 SF									
ENGLISH DEPARTMENT		N	1,600 SF									
HEALTH		N	600 SF									
ROOM 105		N	720 SF									
GUIDANCE		N	1,000 SF									
ROOM 103		N	720 SF									
ROOM 101		N	500 SF									
COMMUNICATIONS CLOSET		N	100 SF									
RESOURCES OFFICE		N	70 SF									
MAIN OFFICE		N	1,500 SF									
ROOM 108		N	720 SF									
ROOM 107	N	70 SF										

ASBESTOS TYPE

CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY

SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL

M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS

Y Yes  
N No  
A Assumed

NOTES

HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.



							2022	RESPONSE	SPECIAL	TYPE	
HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	ASSESSMENT 40 CFR 763.88	ACTION START/END DATES	CLEANING NEEDED	OF DAMAGE	RECOMMENDATIONS
				DAM	QUANTITY						REFER TO REPORT FOR DATES AND COST ESTIMATES
31	2' X 2' SUSPENDED ACOUSTICAL CEILING TILE										
	ROOM 110	7/9/10	N	N	900 SF						
	ROOM 109			N	900 SF						
	ROOM 112			N	900 SF						
	ROOM 111			N	900 SF						
	ROOM 114			N	1,600 SF						
	ROOM 113			N	600 SF						
	ROOM 120			N	1,100 SF						
	ROOM 122			N	1,100 SF						
	MATH-SCIENCE DEPARTMENT			N	900 SF						
	ROOM 124			N	1,200 SF						
	MATH-SCIENCE COMPUTER LAB			N	600 SF						
	ROOM 121			N	750 SF						
	ROOM 126			N	1,200 SF						
	ROOM 123			N	750 SF						
	ROOM 128			N	1,200 SF						
	ROOM 125			N	750 SF						
	ROOM 200			N	900 SF						
	ROOM 201			N	900 SF						
	ROOM 202			N	900 SF						
	ROOM 203			N	900 SF						
	ROOM 204			N	900 SF						
	ROOM 205			N	900 SF						
	ROOM 206			N	900 SF						
	ROOM 207			N	570 SF						
	ROOM 208			N	570 SF						
	ROOM 209			N	1,500 SF						
	ROOM 210			N	450 SF						
	ROOM 212			N	450 SF						
	PSYCHOLOGY OFFICE			N	100 SF						
	READING-SPEECH OFFICE			N	100 SF						
	FACULTY ROOM			N	660 SF						
	OFFICE A			N	250 SF						
	CUSTODIAN OFFICE			N	350 SF						
	OFFICE B			N	100 SF						
	OFFICE C			N	100 SF						
CONFERENCE ROOM	N			230 SF							
LIBRARY	N	6,200 SF									
LIBRARY OFFICE	N	500 SF									
ROOM 400	N	900 SF									

ASBESTOS TYPE  
CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY  
SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL  
M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS  
Y Yes  
N No  
A Assumed

NOTES  
HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.

							2022	RESPONSE	SPECIAL	TYPE	
HOM. AREA	DESCRIPTION	SAMPLE DATE	ASBESTOS (Y/N/A)			FRIABLE	ASSESSMENT 40 CFR 763.88	ACTION START/END DATES	CLEANING NEEDED	OF DAMAGE	RECOMMENDATIONS
				DAM	QUANTITY						REFER TO REPORT FOR DATES AND COST ESTIMATES
31	2' X 2' SUSPENDED ACOUSTICAL CEILING TILE										
	ROOM 402	7/9/10	N	N	900 SF						
	ROOM 401 ART			N	1,200 SF						
	LANGUAGE OFFICE			N	600 SF						
	ROOM 403 ART			N	1,200 SF						
	ROOM 404 HEALTH			N	600 SF						
	ROOM 300			N	820 SF						
	MAIN HALLWAYS			N	10,000 SF						
	ROOM 301 MUSIC			N	1,600 SF						
	COPY ROOM			N	100 SF						
	MAIN LOBBY			N	2,000 SF						
	SCHOOL STORE			N	200 SF						
	ROOM 99 CONFERENCE			N	460 SF						

ASBESTOS TYPE  
CHRY Chrysotile  
AMOS Amosite  
ACTI Actinolite  
ANTH Anthophyllite  
CROC Crocidolite  
NA/PS Not Analyzed/Positive Stop

QUANTITY  
SF Square Feet  
LF Linear Feet  
EA Each  
TO Total

TYPE OF MATERIAL  
M Miscellaneous  
S Surfacing  
T Thermal

ASBESTOS  
Y Yes  
N No  
A Assumed

NOTES  
HV - HEPA VACCUUM  
2X/WK - TWICE PER WEEK  
1X/WK - ONCE PER WEEK  
L - LOOSE  
DE - DETERRIORATED  
D - DAMAGED  
SD - SIGNIFICANT DAMAGE

- (1) Damaged or significantly damaged thermal system insulation ACM.
- (2) Damaged friable surfacing ACM.
- (3) Significantly damaged friable surfacing ACM.
- (4) Damaged or significantly damaged friable miscellaneous ACM.
- (5) ACBM with potential for damage.
- (6) ACBM with potential for significant damage.
- (7) Any remaining friable ACBM or friable suspected ACBM.